

Appendix G

Noise Monitoring Data

Table G 1 Summary of Noise Monitoring Result

Date	Time	Weather	Leq-5min, dB(A)						Leq-30min, dB(A)	L10-30mins, dB(A)	L90-30mins, dB(A)	Limit Level, dB(A)*	Noise Meter
			Reading (1)	Reading (2)	Reading (3)	Reading (4)	Reading (5)	Reading (6)					
3/5/2023	11:48 - 12:18	Sunny	66.7	63.6	64.3	64.9	66.5	67.9	65.9	69.7	62.5	70.0	Lutron, SL-4033SD
13/5/2023	11:54 - 12:24	Fine	68.8	67.3	66.5	69.2	68.4	67.7	68.1	72.1	64.1	70.0	Lutron, SL-4033SD
19/5/2023	11:39 - 12:09	Sunny	65.5	68.3	67.4	66.8	65.1	64.9	66.5	69.6	62.4	70.0	Lutron, SL-4033SD
25/5/2023	11:52 - 12:22	Sunny	66.9	66.0	68.8	67.3	69.8	67.2	67.9	70.3	63.5	70.0	Lutron, SL-4033SD
31/5/2023	11:42 - 12:12	Sunny	67.6	69.4	67.5	66.1	65.9	66.8	67.4	70.4	63.0	70.0	Lutron, SL-4033SD

Remarks:

*No examinations were scheduled for NSR4 Creative Secondary School in the reporting month.