

Appendix G

Noise Monitoring Data

The copyright of this document is owned by Acuity Sustainability Consulting Limited. It may not be reproduced except with prior written approval from the Company.



Table G 1Summary of Noise Monitoring Result

Date	Time	Weather	Leq-5min, dB(A)						Leq-30min,	L10-30mins,	L90-30mins	Limit	
			Reading (1)	Reading (2)	Reading (3)	Reading (4)	Reading (5)	Reading (6)	dB(A)	dB(A)	dB(A)	Level, dB(A)*	Noise Meter
03/11/2023	10:45 - 11:15	Sunny	69.7	70.2	71.7	68.9	68.1	70	69.9	72.7	63.8	70.0	SVANTEK 971
9/11/2023	10:52 - 11:22	Sunny	62.0	60.6	63.1	60	61.8	60.7	61.5	64.4	57.5	70.0	SVANTEK 971
15/11/2023	10:45 - 11:15	Fine	65.2	63.8	64.5	62.4	64.9	62.4	64.0	67.1	61.0	70.0	SVANTEK 971
21/11/2023	11:01 - 11:31	Sunny	63.1	61.9	62.3	63.8	61.2	64.9	63.0	65.4	59.8	70.0	SVANTEK 971
27/11/2023	10:49 - 11:19	Sunny	64.5	65.7	63.0	62.8	61.9	64.5	63.9	66.1	61.6	70.0	SVANTEK 971

The copyright of this document is owned by Acuity Sustainability Consulting Limited. It may not be reproduced except with prior written approval from the Company.